

C E R T I F I C A T E
of Conformity
EC Council Directive 2014/30/EU
Electromagnetic Compatibility



Registration No.: AE 50477053 0001

Report No.: 50254512 001

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
(PV Grid-connected Inverter)

Identification: Type Designation: R5-3K-T2 R5-4K-T2 R5-5K-T2
R5-6K-T2 R5-8K-T2 R5-9K-T2
R5-10K-T2 R5-12K-T2
Serial No. : n.a.
Remark: Refer to above-listed test report for details.

Tested acc. to: EN 61000-6-1:2007
EN 61000-6-2:2005
EN 61000-6-3:2007+A1
EN 61000-6-4:2007+A1

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.

Date 06.08.2020



Certification Body

Tongle Lee

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may only be used if all relevant and effective EC Directives are complied with. **CE**

Guangzhou Sanjing Electric Co.,
Ltd.

Date : 06.08.2020
Our ref. : AOFEL 02
Your ref.:

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AE Certificate of Conformity EMC

Type of Equipment : PV Grid-connected Inverter
Model Designation : See Certificate
Certificate No. : AE 50477053 0001
Report No. : 50254512 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Tongle Lee

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50450771 0001


Report No.: 50270885 001

Holder: Guangzhou Sanjing Electric
Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P. R. China

Product: PV-Inverter
(Grid-tied PV Inverter)

Identification: Type Designation: R5-3K-T2 R5-4K-T2 R5-5K-T2 R5-6K-T2
R5-8K-T2 R5-9K-T2 R5-10K-T2 R5-12K-T2
R5-3K-T2-AUS R5-4K-T2-AUS R5-5K-T2-AUS
R5-6K-T2-AUS R5-8K-T2-AUS R5-9K-T2-AUS
R5-10K-T2-AUS
Serial Number : R5T2123G1847C00542
Remark : Refer to report 50270885 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Date 29.10.2019

A handwritten signature in black ink, appearing to read "A. Chen".
A. Chen

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Guangzhou Sanjing Electric Co.,
Ltd.
Mr. Li Yun

Date : 30.10.2019
Our ref. : zhangco 02
Your ref.: L.Y

-
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P. R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-tied PV Inverter
Model Designation : See Certificate
Certificate No. : AN 50450771 0001
Report No. : 50270885 001

Dear Mr. Li Yun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


A. Chen

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

CERTIFICATE of Conformity



Registration No.: AK 50501365 0001

Report No.: CN21TQ5M 001

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
Grid-connected PV Inverter

Identification: Type Designation: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2,
R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2,
Serial No. : R5T2123G1801C00001, R5T2033G2001C00001,
Firmware version: V3.017
Remark: Refer to test report CN21TQ5M 001 for details.

Tested acc. to: UNE 206006 IN:2011
UNE 206007-1 IN:2013
RD 1699:2011
RD 661:2007
RD 413:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 19.04.2021

A handwritten signature in blue ink, appearing to read "A. Chen".
A. Chen

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CERTIFICADO

de conformidad



Adjunto a
Attachment to

Número de registro: AK 50501365 0001
Registration No.

Reporte no: CN21TQ5M 001
Report No.

Titular de la licencia: Guangzhou Sanjing Electric Co., Ltd.
License Holder No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong P. R. China

Tipo de producción: Conectado a la red PV Inversor
Type of production

Modelo: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2,
Model R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2

Versión de firmware: V3.017
Firmware version

Normas: UNE 206006:2011 IN
Standards Ensayos de detección de funcionamiento en isla de múltiples inversores fotovoltaicos conectados a red en paralelo
UNE 206007-1:2013 IN
Requisitos de conexión a la red eléctrica Parte 1: Inversores para conexión a la red de distribución
RD1699/2011
Real Decreto 1699/2011, de 18 de noviembre, por el que se regula la conexión a red de instalaciones de producción de energía eléctrica de pequeña potencia.
RD 661/2007
Real Decreto 661/2007, de 25 de mayo, por el que se regula la actividad de producción de energía eléctrica en régimen especial.
RD 413/2014
Real Decreto 413/2014, de 6 de junio, por el que se regula la actividad de producción de energía eléctrica a partir de fuentes de energía renovables, cogeneración y residuos.

Fecha de emisión: 19.04.2021
Date of issue

Válido hasta el: 18.04.2024
Valid until the

El certificado de conformidad se refiere al producto mencionado anteriormente. Esto es para certificar que el espécimen está en conformidad con el requisito de evaluación mencionado anteriormente. Este certificado no implica una evaluación de la producción del producto y no permite el uso de una marca de conformidad TÜV Rheinland.

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Guangzhou Sanjing Electric Co.,
Ltd.

Date : 19/04/2021
Our ref. : 02
Your ref.: 168312649

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50501365 0001
Report No. : CN21TQ5M 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



A. Chen

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50522592 0001

Report No.: CN21ACEC 001

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
(Grid-connected PV Inverter)

Identification: Type Designation: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2,
R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15,
R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15,
R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15, R5-3K-T2-AUS,
R5-4K-T2-AUS, R5-5K-T2-AUS, R5-6K-T2-AUS, R5-8K-T2-AUS,
R5-9K-T2-AUS, R5-10K-T2-AUS
Serial Number : A003148931-004, A003148931-003

Remark : Refer to test report CN21ACEC 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Date 27.10.2021

A. Chen

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives are complied with.



Guangzhou Sanjing Electric Co.,
Ltd.

Date : 27.10.2021
Our ref. : PJG 02
Your ref.: 168330287

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Grid-connected PV Inverter
Model Designation : See Certificate
Certificate No. : AN 50522592 0001
Report No. : CN21ACEC 001

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



A. Chen

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E
of Conformity
EC Council Directive 2014/30/EU
Electromagnetic Compatibility

Registration No.: AE 50551114 0001

Report No.: 50254512 003

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
(PV Grid-connected Inverter)

Identification: R5-3K-T2 R5-4K-T2 R5-5K-T2 R5-6K-T2 R5-8K-T2
R5-9K-T2 R5-10K-T2 R5-12K-T2 R5-3K-T2-15
R5-4K-T2-15 R5-5K-T2-15 R5-6K-T2-15 R5-8K-T2-15
R5-9K-T2-15 R5-10K-T2-15 R5-12K-T2-15
Serial No.: n.a.
Remark: Refer to above-listed test report for details.

Tested acc. to: EN IEC 61000-6-1:2019
EN IEC 61000-6-2:2019
EN IEC 61000-6-3:2021
EN IEC 61000-6-4:2019

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.



Certification Body



Tongle Lee

Date 12.07.2022

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Guangzhou Sanjing Electric Co.,
Ltd.

Date : 12.07.2022
Our ref. : AOFEL 02
Your ref.:

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AE Certificate of Conformity EMC

Type of Equipment : PV Grid-connected Inverter
Model Designation : See Certificate
Certificate No. : AE 50551114 0001
Report No. : 50254512 003

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Tongle Lee

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E
of Conformity
EC Council Directive 2014/30/EU
Electromagnetic Compatibility

Registration No.: AE 50532264 0001

Report No.: 50254512 002

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
(PV Grid-connected Inverter)

Identification: R5-3K-T2 R5-4K-T2 R5-5K-T2 R5-6K-T2 R5-8K-T2
R5-9K-T2 R5-10K-T2 R5-12K-T2 R5-3K-T2-15
R5-4K-T2-15 R5-5K-T2-15 R5-6K-T2-15 R5-8K-T2-15
R5-9K-T2-15 R5-10K-T2-15 R5-12K-T2-15
Serial No.: n.a.
Remark: Refer to above-listed test report for details.

Tested acc. to: EN 61000-6-1:2007
EN 61000-6-2:2005
EN 61000-6-3:2007+A1
EN 61000-6-4:2007+A1

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2014/30/EU. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.

Date 24.01.2022



Certification Body

Tongle Lee

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Guangzhou Sanjing Electric Co.,
Ltd.

Date : 24.01.2022
Our ref. : AOFEL 02
Your ref.:

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AE Certificate of Conformity EMC

Type of Equipment : PV Grid-connected Inverter
Model Designation : See Certificate
Certificate No. : AE 50532264 0001
Report No. : 50254512 002

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Tongle Lee

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询



广州三晶电气股份有限公司

Guangzhou Sanjing Electric Co., Ltd.

Tel : 400-159-0088

Fax : 020-66608589

Web : www.saj-electric.cn / www.saj-electric.com

地址：广州高新技术产业开发区科学城荔枝山路9号三晶创新园

Add: SAJ Innovation Park, No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China.

EU Declaration of Conformity

We Guangzhou Sanjing Electric Co., Ltd.

No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China

Declare under our own responsibility that the product

Name/Trademark:



Model:

Single phase inverter: R5-0.7K-S1, R5-1K-S1, R5-1.5K-S1, R5-2K-S1, R5-2.5K-S1, R5-3K-S1,
R5-3K-S2, R5-3.6K-S2, R5-4K-S2, R5-5K-S2, R5-6K-S2, R5-7K-S2,
R5-8K-S2

Three-phase inverter: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2,
R5-10K-T2, R5-12K-T2, R5-13K-T2, R5-15K-T2, R5-17K-T2, R5-20K-T2

Comply with the following directives and regulations:

- 2014/35/EU (Low Voltage Directive)
- 2014/30/EU (EMC Directive)
- 2011/65/EU (RoHS Directive)
- DIRECTIVE (EU) 2015/863

For the evaluation of the compliance with these Directives and Regulations, the following standards/requirements were applied:

Safety: EN 62109-1:2010

EN 62109-2:2011

EMC: EN 61000-6-1:2007

EN 61000-6-2:2005,

EN 61000-6-3:2007+A1:2011

EN 61000-6-4:2007+A1:2011

EN 61000-3-2:2014(Maximum AC current $\leq$ 16A)

EN 61000-3-3:2013(Maximum AC current $\leq$ 16A)

EN 61000-3-11:2000(Maximum AC current $>$ 16A)

EN 61000-3-12:2011(Maximum AC current $>$ 16A)

RoHS: EN 50581: 2012

Notified Bodies: TÜV Rheinland

INTERTEK

Guangzhou

Place

December 21, 2020

Date

Director of New Energy: Li Yun

Signature

Li Yun



广州三晶电气股份有限公司

Guangzhou Sanjing Electric Co., Ltd.

Tel : 400-159-0088 Fax : 020-66608589

Web : www.saj-electric.cn / www.saj-electric.com

地址 : 广州高新技术产业开发区科学城荔枝山路9号三晶创新园

Add: SAJ Innovation Park, No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China.

EU Declaration of Conformity

We Guangzhou Sanjing Electric Co., Ltd.

No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China

Declare under our own responsibility that the product

Name/Trademark:



Model:

Single phase inverter: R5-0.7K-S1, R5-1K-S1, R5-1.5K-S1, R5-2K-S1, R5-2.5K-S1, R5-3K-S1,
R5-3K-S2, R5-3.6K-S2, R5-4K-S2, R5-5K-S2, R5-6K-S2, R5-7K-S2,
R5-8K-S2

Three-phase inverter: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2,
R5-10K-T2, R5-12K-T2, R5-13K-T2, R5-15K-T2, R5-17K-T2, R5-20K-T2

Comply with the following directives and regulations:

- 2014/35/EU (Low Voltage Directive)
- 2014/30/EU (EMC Directive)
- 2011/65/EU (RoHS Directive)
- DIRECTIVE (EU) 2015/863

For the evaluation of the compliance with these Directives and Regulations, the following standards/requirements were applied:

Safety: EN 62109-1:2010

EN 62109-2:2011

EMC: EN 61000-6-1:2007

EN 61000-6-2:2005,

EN 61000-6-3:2007+A1:2011

EN 61000-6-4:2007+A1:2011

EN 61000-3-2:2014(Maximum AC current $\leq 16A$)

EN 61000-3-3:2013(Maximum AC current $\leq 16A$)

EN 61000-3-11:2000(Maximum AC current $> 16A$)

EN 61000-3-12:2011(Maximum AC current $> 16A$)

RoHS: EN 50581: 2012

Notified Bodies: TÜV Rheinland

INTERTEK

Guangzhou

Place

December 21, 2020

Date

Director of New Energy: Li Yun

Signature


Certificado de Conformidad

Número de certificado: CN-PV-220132

Conforme a los ensayos realizados, la muestra<s> del producto que se detalla a continuación se ajusta a los requisitos de la especificación<s>/norma<s> de referencia en el momento en que se realizaron los ensayos. Esto no implica que Intertek haya realizado ningún tipo de vigilancia o control de la(s) fabricación(es). El o los fabricantes se asegurarán de que el proceso de fabricación cumpla con los productos examinados mencionados en este certificado.

Solicitante:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Producto:	Inversor Fotovoltaico Conectado a la Red
Calificaciones y Características Principales:	Véase el apéndice del Certificado de Conformidad
Modelo:	R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15
Nombre de la Marca<s>:	
Producto Conforme con:	NTS-631:2020 Norma técnica para el control de conformidad de los módulos de generación de energía según el Reglamento UE 2016/631
Nombre y Dirección de la Oficina Emisora del Certificado:	Intertek Testing Services Ltd.Shanghai West Area, 2 nd Floor, No.707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai,P.R.China Acreditado por ACCREDIA de conformidad con la norma ISO/IEC 17065:2012
Informe de la Prueba<s> N°.:	220614051GZU-001

Información Complementaria en el Apéndice.



Firma

Responsable de la Certificación: Grady
Fecha: 06 de julio de 2022



PRD N° 306B

El presente Certificado está destinado al uso exclusivo del cliente de Intertek y se entrega en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad y la obligación de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente según el acuerdo, por cualquier pérdida, gasto, o daño ocasionado por el uso de este Certificado. Únicamente el Cliente está autorizado a conceder la copia o distribución de este Certificado. El uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto, o servicio examinado debe ser aprobado previamente por escrito por Intertek.

APÉNDICE: Certificado de Conformidad

Este es un Apéndice del Certificado de Conformidad Número: CN-PV-220132.

Unidad / Tipo.....:	R5-3K-T2, R5-3K-T2-15	R5-4K-T2, R5-4K-T2-15	R5-5K-T2, R5-5K-T2-15	R5-6K-T2, R5-6K-T2-15	R5-8K-T2, R5-8K-T2-15	R5-9K-T2, R5-9K-T2-15	R5-10K-T2, R5-10K-T2-15	R5-12K-T2, R5-12K-T2-15
Versión de hardware / Número de serie (examinado)..... :	V1.3							
Versión del firmware / Versión del software (examinado)..... :	V3.055							
Rango de Corriente Continua MPP a plena carga [V]..... :	520-880							
Rango de entrada de Corriente Continua [V]..... :	160-950							
Entrada máxima de Corriente Continua [A]..... :	12.5/12.5 ¹⁾ or 15/15 ²⁾							
Máximo de Cortocircuito [A]..... :	15/15 ¹⁾ or 18/18 ²⁾							
Tensión nominal de salida de CA [V]..... :	230/400V (3~ + N + PE, 50/60Hz)							
Salida máxima de Corriente Alterna [A] :	5,0	6,7	8,4	10,0	13,4	15,0	16,7	18,2
Potencia activa nominal de salida [kW] :	3,0	4,0	5,0	6,0	8,0	9,0	10,0	12,0
Potencia de salida máxima, aparente / activa [kVA / kW]..... :	3,3	4,4	5,5	6,6	8,8	9,9	11,0	12,0

1) Corriente de entrada máxima (A) = 12,5 y máximo de cortocircuito (A) = 15A para R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2.

2) Corriente de entrada máxima (A) = 15 y máximo de cortocircuito (A) = 18A para R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15.

APÉNDICE: Certificado de Conformidad

Este es un Apéndice del Certificado de Conformidad Número: CN-PV-220132.

Requisito / Requirement	NTS	Tipo / Type	Cumplimiento / Complicant	Nombre Entidad Emisora / Name of issuing Entity	Ev.(*)
Modo regulación potencia-frecuencia limitado sobrefrecuencia (MRPFL-O) / Power-frequency regulation mode limited to overfrequency (MRPFL-O)	5.1	≥A	YES (TRF No.220614051GZ U-001)	Intertek	P
Modo regulación potencia-frecuencia limitado-subfrecuencia (MRPFL-U) / Power-frequency regulation mode limited to underfrequency (MRPFL-U)	5.2	≥C	NOT APPLICABLE	--	--
Modo regulación potencia-frecuencia (MRPF) / Power-frequency regulation mode (MRPF)	5.3	≥C	NOT APPLICABLE	--	--
Control de potencia-frecuencia / Frequency Control	5.4	≥C	NOT APPLICABLE	--	--
Capacidad de control y el rango de control de la potencia activa en remote / Active Power Requirements	5.5	≥C	NOT APPLICABLE	--	--
Emulación de inercia durante variaciones de frecuencia muy rápidas / Inertia Emulations	5.6	≥C	NOT APPLICABLE	--	--
Capacidad de potencia reactiva a la capacidad máxima y por debajo / Reactive power capabilities at the EUT rated power and below	5.7	≥B	NOT APPLICABLE	--	--
Modos de control de la potencia reactiva / Reactive power control modes	5.8	≥B	NOT APPLICABLE	--	--
Control de amortiguamiento de oscilaciones / Control of oscillation damping	5.10	≥C	NOT APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por debajo de 110 kV / Capability to withstand voltage grid faults for POC below 110 kV	5.11	≥B	NOT APPLICABLE	--	--
Capacidad para soportar huecos de tensión de los MPE conectados por encima de 110 kV / Capability to withstand voltage grid faults for POC above 110 kV	5.11	D	NOT APPLICABLE	--	--
Recuperación de la potencia activa después de una falta / Active power recovery after a grid fault	5.11	≥B	NOT APPLICABLE	--	--
Inyección rápida de corriente de falta en el punto de conexión en caso de faltas trifásicas / Rapid current injection control	5.11	≥B	NOT APPLICABLE	--	--
Capacidad de participar en el funcionamiento en isla / Islanding requirements	5.13	≥C	NOT APPLICABLE	--	--
(*) Evaluado por / Evaluated by: P: Prueba de conformidad / Test of compliance S: Simulación de conformidad / Simulation of compliance					

Declaration: It is an accurate translation of the original document.

El presente Certificado está destinado al uso exclusivo del cliente de Intertek y se entrega en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad y la obligación de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente según el acuerdo, por cualquier pérdida, gasto, o daño ocasionado por el uso de este Certificado. Únicamente el Cliente está autorizado a conceder la copia o distribución de este Certificado. El uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto, o servicio examinado debe ser aprobado previamente por escrito por Intertek.

Certificate of Conformity

Certificate Number: CN-PV-190098

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Product:	Anti-backflow system
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Model:	PV Grid-connected Inverter: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-13K-T2,R5-15K-T2,R5-17K-T2,R5-20K-T2 Three phase smart meter: DTSU666
Brand Name:	
Tested according to:	UNE 217001 IN: October 2015 Requirements and tests for systems intended to avoid the energy transmission to the distribution network
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
Test Report No.:	191115099GZU-001

Additional information in Appendix.

Signature

Certification Manager: Grady Ye

Date: 07 January 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle
Characteristics:

PV Grid-connected Inverter:

Model	R5-3K-T2	R5-4K-T2	R5-5K-T2	R5-6K-T2	R5-8K-T2	R5-9K-T2
Max Voltage	1100 Vdc					
MPPT voltage range	160-950 Vdc					
Max DC input Current [PV1/PV2]	12.5/12.5 Adc					
Max. Short circuit Current [PV1/PV2]	15/15Adc					
Nominal AC voltage	3W/N/PE, 230/400Vac					
Rated AC current [A]	4.4	5.8	7.3	8.7	11.6	13.1
Max.AC Current [A]	5.0	6.7	8.4	10.0	13.4	15.0
Grid Frequency	50Hz					
Rated Power [W]	3000	4000	5000	6000	8000	9000
Max. AC power [VA]	3300	4400	5500	6600	8800	9900
Power factor	0.8 Leading to 0.8 Lagging					
Temperature	-40°C - +60°C					
Protective Class	Class I					
Ingress protection	IP 65					
Software Version	V3.025					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle Characteristics:

Model	R5-10K-T2	R5-12K-T2	R5-13K-T2	R5-15K-T2	R5-17K-T2	R5-20K-T2
Max Voltage	1100 Vdc					
MPPT voltage range	160-950 Vdc				180-950 Vdc	
Max DC input Current	12.5/12.5 Adc		25/12.5 Adc		25/25 Adc	
Max. Short circuit Current	15/15 Adc		30/15 Adc		30/30 Adc	
Nominal AC voltage	3W/N/PE, 230/400Vac					
Rated AC current [A]	14.5	17.4	18.9	21.8	24.7	29.0
Max.AC Current [A]	16.7	18.2	21.7	25.0	28.4	33.4
Grid Frequency	50Hz					
Rated Power [W]	1000	12000	13000	15000	17000	20000
Max. AC power [VA]	11000	12000	14300	16500	18700	22000
Power factor	0.8 Leading to 0.8 Lagging					
Temperature	-40°C - +60°C					
Protective Class	Class I					
Ingress protection	IP 65					
Software Version	V3.025					


This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle
Characteristics:

Three phase smart meter:
Voltage: 3 x 230/400V
Current: Max.80A
Frequency: 50/60Hz
Measurement categories: II
Type of communication: RS485
Operational temperature: -40°C - +60°C
Ingress protection: IP 54
Overvoltage category: II
Pollution degree: 2
Software Version: communication: V1.011



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Verificación de Ensayo de Conformidad

Número de Verificación: 220825091GZU-VOC006

Sobre la base de el(los) informe(s) de ensayo referenciado(s), se ha comprobado que la(s) muestra(s) ensayada(s) del producto indicado a continuación cumple(n) con los estándares armonizados con las directivas enumeradas en esta verificación en el momento en que se realizaron los ensayos. Otros estándares y otras directivas pueden ser pertinentes para el producto. Esta verificación forma parte de el(los) informe(s) de ensayo completo(s) y debe leerse junto con ellos. Esta verificación sustituye a la anterior.

Una vez verificada la conformidad con todas las directivas de la marca **CE** pertinentes para el producto, incluida cualquier evaluación de riesgos y control de producción pertinente, el fabricante puede indicar la conformidad firmando él mismo una Declaración de Conformidad y aplicando la marca a productos idénticos a la(s) muestra(s)

Nombre y Dirección del Solicitante:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Descripción del Producto:	Inversor PV conectado a la Red
Referencias de Modelos/Tipo:	R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15
Calificaciones y Características Principales:	Ver apéndice
Nombre de la Marca:	SAJ
Estándares/Directivas Pertinentes:	EN IEC 61000-6-3:2021 EN IEC 61000-6-1:2019 EN IEC 61000-6-4:2019 EN IEC 61000-6-2:2019 EMC Directive 2014/30/EU
Nombre & Dirección de la Oficina Emisora de la Verificación:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Fecha de Ensayos:	-
Número(s) de Informe de Ensayo:	220825091GZU-006
Información Adicional en el Apéndice.	

Sky Zhu

Firma

Nombre: Sky Zhu

Posición: Jefe de equipo

Fecha: 16 de septiembre de 2022



Esta Verificación es para uso exclusivo del cliente de Intertek y se proporciona en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente de conformidad con el acuerdo, por cualquier pérdida, gasto o daño ocasionado por el uso de esta Verificación. Sólo el Cliente está autorizado a permitir la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio ensayado debe ser aprobado previamente por escrito por Intertek. Las observaciones y los resultados de los ensayos/inspecciones a los que se hace referencia en esta Verificación son pertinentes únicamente para la muestra ensayada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.

APÉNDICE: Verificación de Ensayo de Conformidad

Éste es un Apéndice de la Verificación de Ensayo de Conformidad N°: 220825091GZU-VOC006

Calificaciones y Características Principales:

Modelo	R5-3K-T2, R5-3K-T2-15, R5-3K-T2-AUS	R5-4K-T2, R5-4K-T2-15, R5-4K-T2-AUS	R5-5K-T2, R5-5K-T2-15, R5-5K-T2-AUS	R5-6K-T2, R5-6K-T2-15, R5-6K-T2-AUS
Tensión Máx. PV	1100Vdc; 600Vdc (for suffix with '-AUS' models)			
Tensión MPPT	160-950Vdc; 160-550Vdc (for suffix with '-AUS' models)			
Corriente Máx. de Entrada	12.5A/12.5A, 15A/15A (for suffix with '-15' models)			
PV Isc	15A/15A, 18A/18A (for suffix with '-15' models)			
Tensión Nominal de Salida	3/N/PE, 230Vac/400Vac			
Frecuencia Nominal de Salida	50/60Hz			
Corriente Máx. de Salida	5.0A	6.7A	8.4A	10.0A
Potencia Nominal de Salida	3.0KW	4.0KW	5.0KW	6.0KW
Potencia Aparente Máx.	3.3KVA	4.4KVA	5.5KVA	6.6KVA
Rango del Factor de Potencia	0.8Leading~0.8Lagging			
Nivel de Seguridad	Class I			
Grado de Protección	IP 65			
Temperatura Ambiente de Funcionamiento	-25°C - +60°C (>45°C with derating)			
Firmware	V3.036			

Sky Zhu

Firma

Nombre: Sky Zhu

Posición: Jefe de equipo

Fecha: 16 de septiembre de 2022



Esta Verificación es para uso exclusivo del cliente de Intertek y se proporciona en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente de conformidad con el acuerdo, por cualquier pérdida, gasto o daño ocasionado por el uso de esta Verificación. Sólo el Cliente está autorizado a permitir la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio ensayado debe ser aprobado previamente por escrito por Intertek. Las observaciones y los resultados de los ensayos/inspecciones a los que se hace referencia en esta Verificación son pertinentes únicamente para la muestra ensayada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.

APÉNDICE: Verificación de Ensayo de Conformidad

Éste es un Apéndice de la Verificación de Ensayo de Conformidad N°: 220825091GZU-VOC006

Calificaciones y
Características
Principales:

Modelo	R5-8K-T2, R5-8K-T2-15, R5-8K-T2-AUS	R5-9K-T2, R5-9K-T2-15, R5-9K-T2-AUS	R5-10K-T2, R5-10K-T2-15, R5-10K-T2- AUS	R5-12K-T2 R5-12K-T2-15
Tensión Máx. PV	1100Vdc; 600Vdc (for suffix with '-AUS' models)			
Tensión MPPT	160-950Vdc; 160-550Vdc (for suffix with '-AUS' models)			
Corriente Máx. de Entrada	12.5A/12.5A; 11A/22A (for suffix with '-AUS' models); 15A/15A (for suffix with '-15' models)			
PV Isc	15A/15A; 13.2A/26.4A (for suffix with '-AUS' models); 18A/18A (for suffix with '-15' models)			
Tensión Nominal de Salida	3/N/PE, 230Vac/400Vac			
Frecuencia Nominal de Salida	50/60Hz			
Corriente Máx. de Salida	13.4A	15.0A	16.7A	18.2A
Potencia Nominal de Salida	8.0KW	9.0KW	10.0KW	12.0KW
Potencia Aparente Máx.	8.8KVA	9.9KVA	11.0KVA	12.0KVA
Rango del Factor de Potencia	0.8Leading~0.8Lagging			
Nivel de Seguridad	Class I			
Grado de Protección	IP 65			
Temperatura Ambiente de Funcionamiento	-25°C - +60°C (>45°C with derating)			
Firmware	V3.036			

Sky Zhu

Firma

Nombre: Sky Zhu

Posición: Jefe de equipo

Fecha: 16 de septiembre de 2022

Declaration: It is an accurate translation of the original document.



Esta Verificación es para uso exclusivo del cliente de Intertek y se proporciona en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek se limita a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, salvo ante el Cliente de conformidad con el acuerdo, por cualquier pérdida, gasto o daño ocasionado por el uso de esta Verificación. Sólo el Cliente está autorizado a permitir la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio ensayado debe ser aprobado previamente por escrito por Intertek. Las observaciones y los resultados de los ensayos/inspecciones a los que se hace referencia en esta Verificación son pertinentes únicamente para la muestra ensayada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.

Verificación de la conformidad de la prueba

Número de verificación: 220825089GZU-VOC006

En base de los informes mencionados sobre las pruebas, se ha comprobado que las muestras probadas del siguiente producto cumplieron con las normas armonizadas con las directivas enumeradas en esta verificación, al momento de la realización de las pruebas. Otras normas y directivas pueden aplicar con el producto. Esta verificación forma parte del informe de pruebas completo y debe leerse junto con él <ellos>.

Una vez que se haya verificado el cumplimiento  de todas las directivas de marca pertinentes al producto, incluyendo las evaluaciones de riesgos y control de producción pertinentes, el fabricante podrá otorgar su conformidad con su firma en una declaración de conformidad, y aplicando la marca a productos idénticos a las muestras probadas.

Nombre y dirección del solicitante:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Descripción del producto:	Inversor PV conectado a red eléctrica
Características de potencia y principios:	Consulte el APÉNDICE: Verificación de la conformidad de las pruebas
Referencias de modelos/tipo:	Consulte el APÉNDICE: Verificación de la conformidad de las pruebas
Nombre de la marca:	
Normas/Directivas relevantes:	IEC/EN 62109-1: 2010 Seguridad de convertidor de energía para usarse con los Sistemas de Energía Fotovoltaicos Parte 1: Requisitos generales IEC/EN 62109-2:2011 Seguridad de los convertidores de energía para usarse con los Sistemas de Energía Fotovoltaicos- Parte 2: Requisitos particulares para inversores De conformidad con la Directiva de Baja Tensión 2014/35/EU Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Nombre y dirección de la oficina a cargo de la verificación:	
Fecha de las pruebas:	10 de agosto de 2021 - 10 de octubre de 2021
Número(s) de informe de prueba:	CN21ACEC 001, tested and issued by TUV Rheinland (Shanghai) Co., Ltd.
Información adicional en el Apéndice.	

Jason Fu

Firma

Nombre: Jason Fu

Posición: Supervisor

Fecha: 06 de septiembre de 2022



Esta Verificación es para el uso exclusivo del cliente de Intertek y se da en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek está limitada a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, excepto por Cliente de conformidad con el acuerdo, por las pérdidas, gastos o daños ocasionados por el uso de esta Verificación. El Cliente es el único autorizado a dar lugar a la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio testado debe ser aprobado por escrito por Intertek con anterioridad. Las observaciones y los resultados de las pruebas/inspecciones a los que se hace referencia en esta Verificación son relevantes únicamente para la muestra probada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.

APÉNDICE: Verificación de la conformidad de la prueba

Este es un apéndice de la Prueba de verificación de conformidad Número: 220825089GZU-VOC006

Características de potencia y principios:

Modelo	R5-3K-T2, R5-3K-T2-15, R5-3K-T2-AUS	R5-4K-T2, R5-4K-T2-15, R5-4K-T2-AUS	R5-5K-T2, R5-5K-T2-15, R5-5K-T2-AUS	R5-6K-T2, R5-6K-T2-15, R5-6K-T2-AUS
Tensión PV máx.	1100Vdc; 600Vdc (for suffix with '-AUS' models)			
Tensión MPPT	160-950Vdc; 160-550Vdc (for suffix with '-AUS' models)			
Entrada máxima corriente	12.5A/12.5A, 15A/15A (for suffix with '-15' models)			
PV Isc	15A/15A, 18A/18A (for suffix with '-15' models)			
Tensión nominal de salida	3/N/PE, 230Vac/400Vac			
Frecuencia nominal de salida	50/60Hz			
Corriente de salida máx.	5.0A	6.7A	8.4A	10.0A
Energía nominal de salida	3.0KW	4.0KW	5.0KW	6.0KW
Energía aparente máx.	3.3KVA	4.4KVA	5.5KVA	6.6KVA
Rango del factor de potencia	0.8Leading~0.8Lagging			
Nivel de seguridad	Class I			
Protección contra el ingreso	IP 65			
Temperatura ambiente de funcionamiento	-25°C - +60°C (>45°C with derating)			
Firmware	V3.036			

Jason Fu

Firma

Nombre: Jason Fu

Posición: Supervisor

Fecha: 06 de septiembre de 2022



Esta Verificación es para el uso exclusivo del cliente de Intertek y se da en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek está limitada a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, excepto por Cliente de conformidad con el acuerdo, por las pérdidas, gastos o daños ocasionados por el uso de esta Verificación. El Cliente es el único autorizado a dar lugar a la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio testado debe ser aprobado por escrito por Intertek con anterioridad. Las observaciones y los resultados de las pruebas/inspecciones a los que se hace referencia en esta Verificación son relevantes únicamente para la muestra probada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.

APÉNDICE: Verificación de la conformidad de la prueba

Este es un apéndice de la Prueba de verificación de conformidad Número: 220825089GZU-VOC006

Características de potencia y principios:

Modelo	R5-8K-T2, R5-8K-T2-15, R5-8K-T2-AUS	R5-9K-T2, R5-9K-T2-15, R5-9K-T2-AUS	R5-10K-T2, R5-10K-T2-15, R5-10K-T2-AUS	R5-12K-T2 R5-12K-T2-15
Tensión PV máx.	1100Vdc; 600Vdc (for suffix with '-AUS' models)			
Tensión MPPT	160-950Vdc; 160-550Vdc (for suffix with '-AUS' models)			
Entrada máxima corriente	12.5A/12.5A; 11A/22A (for suffix with '-AUS' models); 15A/15A (for suffix with '-15' models)			
PV Isc	15A/15A; 13.2A/26.4A (for suffix with '-AUS' models); 18A/18A (for suffix with '-15' models)			
Tensión nominal de salida	3/N/PE, 230Vac/400Vac			
Frecuencia nominal de salida	50/60Hz			
Corriente de salida máx.	13.4A	15.0A	16.7A	18.2A
Energía nominal de salida	8.0KW	9.0KW	10.0KW	12.0KW
Energía aparente máx.	8.8KVA	9.9KVA	11.0KVA	12.0KVA
Rango del factor de potencia	0.8Leading~0.8Lagging			
Nivel de seguridad	Class I			
Protección contra el ingreso	IP 65			
Temperatura ambiente de funcionamiento	-25°C - +60°C (>45°C with derating)			
Firmware	V3.036			

Jason Fu

Firma

Nombre: Jason Fu

Posición: Supervisor

Fecha: 06 de septiembre de 2022

Declaration: It is an accurate translation of the original document.



Esta Verificación es para el uso exclusivo del cliente de Intertek y se da en virtud del acuerdo entre Intertek y su Cliente. La responsabilidad de Intertek está limitada a los términos y condiciones del acuerdo. Intertek no asume ninguna responsabilidad ante ninguna parte, excepto por Cliente de conformidad con el acuerdo, por las pérdidas, gastos o daños ocasionados por el uso de esta Verificación. El Cliente es el único autorizado a dar lugar a la copia o distribución de esta Verificación. Cualquier uso del nombre de Intertek o de una de sus marcas para la venta o publicidad del material, producto o servicio testado debe ser aprobado por escrito por Intertek con anterioridad. Las observaciones y los resultados de las pruebas/inspecciones a los que se hace referencia en esta Verificación son relevantes únicamente para la muestra probada/inspeccionada. Esta Verificación por sí misma no implica que el material, producto o servicio esté o haya estado alguna vez bajo un programa de certificación de Intertek.


Certificate of Conformity

Certificate Number: CN-PV-230157

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong P.R. China
Product:	PV Grid-Connected Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15
Brand Name<s>:	
Product Complies with:	UNE 217001:2020 Tests for systems that avoid the discharge of energy to the distribution network
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	220411134GZU-002

Additional information in Appendix.



Signature

Certification Manager: Grady Ye
Date: 06 April 2023



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230157

Model list		R5-3K-T2, R5-3K-T2-15	R5-4K-T2, R5-4K-T2-15	R5-5K-T2, R5-5K-T2-15	R5-6K-T2, R5-6K-T2-15
PV INPUT	VMAX PV[Vdc]	1100			
	ISC PV[A]	15/15, 18/18(for suffix with ‘-15’ models)			
	MPPT Voltage Range VMPP[Vdc]	160-950			
	Max. Input Current IMAX [A]	12.5/12.5, 15/15(for suffix with ‘-15’ models)			
	MPPT Full Power Voltage Range [Vdc]	520-880			
	Number of MPPT	2			
	String per MPPT	1/1			
	Backfeed Current [A]	0			
	Overvoltage Category [OVC]	II			
AC Side (ON-Grid)	Rated Output Voltage Ur [Vac]	3L/N/PE,230/400			
	Rated Output Frequency FNETZ [Hz]	50/60			
	Rated Output Power PE [KW]	3000	4000	5000	6000
	Max. Apparent power SEmax [KVA]	3300	4400	5500	6600
	Rated Output Current Ir [A]	3*4.4	3*5.8	3*7.3	3*8.7
	Max. Output Current Imax [A]	3*5.0	3*6.7	3*8.4	3*10.0
	Power Factor (cosφ)	0.8 leading ~ 0.8 lagging			
	THD [V/I](100% full power	< 3%			
	Overvoltage Category [OVC]	III			
CONSTRUCTION	Hardware [Version]	V1.002			
	Firmware [Version]	V3.036			
	Array Insulation Resistance Detection[Ω]	150K			
	Type of inverter	Non-isolated			
	Separated by	Transformerless			
	Type of NS Protection	Integrated			
	Protective Class	Class I			
	Enclosure Protection [IP]	IP65			
	Operating Temperature Range [°C]	-40℃ to +60℃ (45℃ to 60℃ with derating)			
	Pollution degree [PD]	PD3			
Remark:					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230157


Model list		R5-8K-T2, R5-8K-T2-15	R5-9K-T2, R5-9K-T2-15	R5-10K-T2, R5-10K-T2-15	R5-12K-T2, R5-12K-T2-15
PV INPUT	VMAX PV[Vdc]	1100			
	ISC PV[A]	15/15, 18/18(for suffix with ‘-15’ models)			
	MPPT Voltage Range VMPP[Vdc]	160-950			
	Max. Input Current IMAX [A]	12.5/12.5, 15/15(for suffix with ‘-15’ models)			
	MPPT Full Power Voltage Range [Vdc]	520-880			
	Number of MPPT	2			
	String per MPPT	1/1			
	Backfeed Current [A]	0			
	Overvoltage Category [OVC]	II			
AC Side (ON-Grid)	Rated Output Voltage Ur [Vac]	3L/N/PE,230/400			
	Rated Output Frequency FNETZ [Hz]	50/60			
	Rated Output Power PE [KW]	8000	9000	10000	12000
	Max. Apparent power SEmax [KVA]	8800	9900	11000	12000
	Rated Output Current Ir [A]	3*11.6	3*13.1	3*14.5	3*17.4
	Max. Output Current Imax [A]	3*13.4	3*15.0	3*16.7	3*18.2
	Power Factor (cosφ)	0.8 leading ~ 0.8 lagging			
	THD [V/I] (100% full power	< 3%			
	Overvoltage Category [OVC]	III			
CONSTRUCTION	Hardware [Version]	V1.002			
	Firmware [Version]	V3.036			
	Array Insulation Resistance Detection[Ω]	150K			
	Type of inverter	Non-isolated			
	Separated by	Transformerless			
	Type of NS Protection	Integrated			
	Protective Class	Class I			
	Enclosure Protection [IP]	IP65			
	Operating Temperature Range [°C]	-40℃ to +60℃ (45℃ to 60℃ with derating)			
	Pollution degree [PD]	PD3			
Remark:					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230157.

Installation scheme:



Maximum number of inverters to be connected in parallel is:

Using energy meter CHINT DTSU666, maximum number of inverters connected in parallel are 10

Certificate of Conformity

Certificate Number: CN-PV-190098

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Guangzhou Sanjing Electric Co., Ltd. No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Product:	Anti-backflow system
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Model:	PV Grid-connected Inverter: R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-13K-T2,R5-15K-T2,R5-17K-T2,R5-20K-T2 Three phase smart meter: DTSU666
Brand Name:	
Tested according to:	UNE 217001 IN: October 2015 Requirements and tests for systems intended to avoid the energy transmission to the distribution network
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
Test Report No.:	191115099GZU-001

Additional information in Appendix.

Signature

Certification Manager: Grady Ye

Date: 07 January 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle
Characteristics:

PV Grid-connected Inverter:

Model	R5-3K-T2	R5-4K-T2	R5-5K-T2	R5-6K-T2	R5-8K-T2	R5-9K-T2
Max Voltage	1100 Vdc					
MPPT voltage range	160-950 Vdc					
Max DC input Current [PV1/PV2]	12.5/12.5 Adc					
Max. Short circuit Current [PV1/PV2]	15/15Adc					
Nominal AC voltage	3W/N/PE, 230/400Vac					
Rated AC current [A]	4.4	5.8	7.3	8.7	11.6	13.1
Max.AC Current [A]	5.0	6.7	8.4	10.0	13.4	15.0
Grid Frequency	50Hz					
Rated Power [W]	3000	4000	5000	6000	8000	9000
Max. AC power [VA]	3300	4400	5500	6600	8800	9900
Power factor	0.8 Leading to 0.8 Lagging					
Temperature	-40°C - +60°C					
Protective Class	Class I					
Ingress protection	IP 65					
Software Version	V3.025					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle Characteristics:

Model	R5-10K-T2	R5-12K-T2	R5-13K-T2	R5-15K-T2	R5-17K-T2	R5-20K-T2
Max Voltage	1100 Vdc					
MPPT voltage range	160-950 Vdc				180-950 Vdc	
Max DC input Current	12.5/12.5 Adc		25/12.5 Adc		25/25 Adc	
Max. Short circuit Current	15/15 Adc		30/15 Adc		30/30 Adc	
Nominal AC voltage	3W/N/PE, 230/400Vac					
Rated AC current [A]	14.5	17.4	18.9	21.8	24.7	29.0
Max.AC Current [A]	16.7	18.2	21.7	25.0	28.4	33.4
Grid Frequency	50Hz					
Rated Power [W]	1000	12000	13000	15000	17000	20000
Max. AC power [VA]	11000	12000	14300	16500	18700	22000
Power factor	0.8 Leading to 0.8 Lagging					
Temperature	-40°C - +60°C					
Protective Class	Class I					
Ingress protection	IP 65					
Software Version	V3.025					


This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190098

Ratings & Principle
Characteristics:

Three phase smart meter:
Voltage: 3 x 230/400V
Current: Max.80A
Frequency: 50/60Hz
Measurement categories: II
Type of communication: RS485
Operational temperature: -40°C - +60°C
Ingress protection: IP 54
Overvoltage category: II
Pollution degree: 2
Software Version: communication: V1.011



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



Report Reference No......: 220411134GZU-002
Date of issue: 23 Mar 2023
Total number of pages.....: 36 pages

Testing Laboratory	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch	
Address.....	Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China	
Testing location/ address.....	Same as above	
Tested by (name + signature).....:	Rex Liu Engineer	
Approved by (+ signature).....	Jason Fu Supervisor	

Applicant's name Guangzhou Sanjing Electric Co., Ltd.
Address..... No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone,
Guangdong P.R. China

Standard	UNE 217001:2020
Test procedure	Type approval
Non-standard test method.....:	N/A

Test Report Form No. UNE 217001b
Test Report Form(s) Originator Intertek Guangzhou
Master TRF Dated 2021-05

This publication may be reproduced in whole or in part for non-commercial purposes as long as Intertek is acknowledged as copyright owner and source of the material. Intertek takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test item description	PV Grid-connected Inverter
Trade Mark.....	
Manufacturer.....	Guangzhou Sanjing Electric Co., Ltd.
Model/Type reference	R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15

Ratings	Model list		R5-3K-T2, R5-3K-T2- 15	R5-4K-T2, R5-4K-T2- 15	R5-5K-T2, R5-5K-T2- 15	R5-6K-T2, R5-6K-T2- 15
	PV INPUT	VMAX PV[Vdc]	1100			
		ISC PV[A]	15/15, 18/18(for suffix with '-15' models)			
		MPPT Voltage Range VMPP[Vdc]	160-950			
		Max. Input Current IMAX [A]	12.5/12.5, 15/15(for suffix with '-15' models)			
		MPPT Full Power Voltage Range [Vdc]	520-880			
		Number of MPPT	2			
		String per MPPT	1/1			
		Backfeed Current [A]	0			
		Overvoltage Category [OVC]	II			
	AC Side (ON-Grid)	Rated Output Voltage Ur [Vac]	3L/N/PE,230/400			
		Rated Output Frequency FNETZ [Hz]	50/60			
		Rated Output Power PE [KW]	3000	4000	5000	6000
		Max. Apparent power SEmax [KVA]	3300	4400	5500	6600
		Rated Output Current Ir [A]	3*4.4	3*5.8	3*7.3	3*8.7
		Max. Output Current Imax [A]	3*5.0	3*6.7	3*8.4	3*10.0
		Power Factor (cosφ)	0.8 leading ~ 0.8 lagging			
		THD [V/I](100% full power)	< 3%			
		Overvoltage Category [OVC]	III			
	CONSTR	Hardware [Version]	V1.002			
Firmware [Version]		V3.036				

		[KVA]				
		Rated Output Current Ir [A]	3*11.6	3*13.1	3*14.5	3*17.4
		Max. Output Current Imax [A]	3*13.4	3*15.0	3*16.7	3*18.2
		Power Factor (cosφ)	0.8 leading ~ 0.8 lagging			
		THD [V/I] (100% full power)	< 3%			
		Overvoltage Category [OVC]	III			
	CONSTRUCTION	Hardware [Version]	V1.002			
		Firmware [Version]	V3.036			
		Array Insulation Resistance Detection[Ω]	150K			
		Type of inverter	Non-isolated			
		Separated by	Transformerless			
		Type of NS Protection	Integrated			
		Protective Class	Class I			
		Enclosure Protection [IP]	IP65			
		Operating Temperature Range [°C]	-40°C to +60°C (45°C to 60°C with derating)			
		Pollution degree [PD]	PD3			
	Remark:					

List of installation components:

Type of appliance/ Installation.....:	Three-Phase Smart meter / DIN-Rail
Manufacturer / Distributor / Installer:	Zhejiang CHINT Instrument & Meter Co., Ltd.
Brand.....:	CHINT
Model/Type.....:	DTSU666
Rating.....:	230Vac, 0.05~1.5(6)A with CT (Ratio 50:1), 50/60Hz, 6400imp/KWh Power accuracy: Active Class 0.5S, Reactive Class 1 IP51 Firmware Version:3.05

Summary of testing:

Tests performed (name of test and test clause):

All applicable tests

The model R5-12K-T2-15 is type tested.

Testing location:

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Room 02, &
101/E201/E301/E401/E501/E601/E701/E801 of
Room 01 1-8/F., No. 7-2. Caipin Road, Science City,
GETDD, Guangzhou, Guangdong, China

Copy of marking plate

SAJ Guangzhou Sanjing Electric Co., Ltd.
Tel: +86(20) 66608588 Fax: +86(20) 66608589
Web: www.saj-electric.com E-mail: service@saj-electric.com

PV Grid-connected Inverter
Type: R5-12K-T2

PV Input	
Voltage Range	150V-1100Vdc
MPPT Voltage Range	160V-950Vdc
Max. Input Current (PV1/PV2)	12.5/12.5Adc
Max. Short Circuit Current (PV1/PV2)	15/15Adc
Max. Number of Parallel Strings (PV1/PV2)	1/1

AC Output	
Rated Voltage	3/N/PE 380/400V
Rated Current	3*17.4A
Max. Continuous Current	3*18.2A
Rated Frequency	50/60Hz
Rated Power	12000W
Max. Power	13200VA
Power Factor	0.8i...1...0.8c

Temperature: -40°C~60°C
Protective Class: I
Overvoltage Category: II (DC), III (AC)
Ingress protection: IP65

EN 50438 EN 50549 VDE-AR-N4105 AS/NZS 4777.2
CEI 0-21

CE **ROHS**

S/N

P/C

Importer: MADE IN CHINA

SAJ Guangzhou Sanjing Electric Co., Ltd.
Tel: +86(20) 66608588 Fax: +86(20) 66608589
Web: www.saj-electric.com E-mail: service@saj-electric.com

PV Grid-connected Inverter
Type: R5-12K-T2-15

PV Input	
Voltage Range	150V-1100Vdc
MPPT Voltage Range	160V-950Vdc
Max. Input Current (PV1/PV2)	15/15Adc
Max. Short Circuit Current (PV1/PV2)	18/18Adc
Max. Number of Parallel Strings (PV1/PV2)	1/1

AC Output	
Rated Voltage	3/N/PE 380/400V
Rated Current	3*17.4A
Max. Continuous Current	3*18.2A
Rated Frequency	50/60Hz
Rated Power	12000W
Power Factor	0.8i...1...0.8c

Temperature: -40°C~60°C
Protective Class: I
Overvoltage Category: II (DC), III (AC)
Ingress protection: IP65

EN 50438 EN 50549 VDE-AR-N4105 AS/NZS 4777.2
CEI 0-21

CE **ROHS**

S/N

P/C

MADE IN CHINA

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. The other model labels are identical with label above, except the model's name and rating.

Test item particulars:			
Temperature range	-40°C - 60°C		
AC Overvoltage category.....:	☐ OVC I	☐ OVC II	☒ OVC III ☐ OVC IV
DC Overvoltage category	☐ OVC I	☒ OVC II	☐ OVC III ☐ OVC IV
IP protection class	IP 65		
Possible test case verdicts:			
- test case does not apply to the test object.....: N/A (Not applicable)			
- test object does meet the requirement			
- test object does not meet the requirement			
Testing:			
Date of receipt of test item.....:	11 Apr 2022		
Date (s) of performance of tests.....:	11 Apr 2022 – 22 Mar 2023		
General remarks:			
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. When determining for test conclusion, measurement uncertainty of tests has been considered. This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid. Throughout this report a point is used as the decimal separator.			

General product information:

Description of tested item:

The equipment is triple-phase utility-interactive type PV inverter which will be installed and connected to the grid network after installation.

It contains filters for smoothing the output voltage and for EMC, switching and control circuits. Electronic circuits are mounted on a number of PCBs interconnected by appropriate connectors and wires. Power board including electronics components is mounted on the heat sink to earthing by metal screw and spring washer.

There are included a USB and RS485 communication ports which are connected to the monitors to monitor the status of the inverter by proprietary software.

The PV input combiner with 2 string MPPT tracers and each MPPT tracer including two PV input terminals. AC output direct connected to grid and protective earthing are provided by dedicated earthing terminals. Grid is protected combination with a two series of relays as redundant build for ensure the inverter can independent disconnected from grid while a relay was fault.


During fault condition defined in this standard, after the DSP receives the abnormal signal from the relevant protective detection circuit, the relays will operate to disconnect the PV inverter active lines from grid automatically.

The master DSP and slaver DSP has capacity independent disconnected from gird, when any grid fault had happened.


There is a communication RS485 to the computer also can monitor the status of the inverter by proprietary and control the PCE.

The maximum ambient temperature permitted by the manufacturer's specification is 60°C and derate the output power from 45°C.

Block diagram:




Basic outline of the system:



In the grid-connected power generation system, because the user load and light are constantly changing, in order to prevent the grid-connected system from generating electricity in the reverse direction to the power grid, the monitoring meter is added. The inverter communicates with the meter through the RS485 interface to collect the grid-connected port current in real time. And power signals, and calculate the maximum output power limit value of the inverter according to the meter's feedback power and current data, adjust the inverter output power to achieve the anti-backflow function, and maximize the use of photovoltaic modules to generate power;

Control algorithm:



Variable	Statement
Pr	The power detected by the meter. Negative values represent reverse current, while positive values represent absorbed power from the grid.
Pset	Inverter power limit setting
Pinv	Inverter operating output power

$P_{set} = P_{inv} + P_r$; When the current output power of the inverter is greater than the load power, the inverter supplies power to the load and reverses the current to the grid. At this time, it is detected that P_r is negative, and the inverter limit power setting value is reduced;

When the current output power of the inverter is less than the load power, the load must also absorb power from the grid at this time. At this time, it is detected that P_r is a positive value, and the inverter limit power setting value is increased;

Difference of the models:

The models R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15 and R5-12K-T2-15 same as the enclosure size, construction, software logistic and hardware construction, just the output power are different adjustable by software, except the difference as below:

Model	R5-3K-T2, R5-3K-T2-15	R5-4K-T2, R5-4K-T2-15	R5-5K-T2, R5-5K-T2-15	R5-6K-T2, R5-6K-T2-15	R5-8K-T2, R5-8K-T2-15	R5-9K-T2, R5-9K-T2-15	R5-10K-T2, R5-10K-T2-15	R5-12K-T2, R5-12K-T2-15
Output power	3 kW	4 kW	5 kW	6 kW	8 kW	9 kW	10 kW	12 kW
MPPT string	2							
Max. Input Current I_{MAX} [A] (A/B) (each MPPT)	12.5/12.5 ¹⁾ or 15/15 ²⁾							
Max. Short circuit current (A)	15/15 ¹⁾ or 18/18 ²⁾							
BUS capacitor	2				4			

Note:

1) Max. Input current (A) = 12.5 and Max. Short circuit(A) =15A for R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2.


2) Max. Input current (A) = 15 and Max. Short circuit(A) =18A for R5-3K-T2-15, R5-4K-T2-15, R5-5K-T2-15, R5-6K-T2-15, R5-8K-T2-15, R5-9K-T2-15, R5-10K-T2-15, R5-12K-T2-15.

The testings were performed on:

Hardware version: V1.002

Firmware version: V3.036

Maximum power injected during the registration time, in Watts. Negative values indicate that the inverter and load system consume, i.e. there is no power injection into the network, in those cases, the consumption values closest to the power injection have been taken.



In the results tables are positive the power injection values from the inverter to loads, and negative the values consumed by the loads. Values from network to loads are also negative, so if injection from the inverter to the net would occur this would look like positive values.

No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R. China

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict
3	Installation configuration		P
3.1	Measurement of energy exchange with the grid		P
3.2	Consumption measurement		P
4	Essays		P
4.1	Permanent tolerance		P
4.2	Response to load disconnections		P
4.3	Response to power increases in the primary energy source		P
4.4	Action in case of loss of communications		P
4.5	Determination of the maximum number of generators	N _{max} : 10	P

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

4.1	Permanent tolerance						P
	Test No.	Load			Power injection to the grid (W)	Tolerance (%)	Limit
Single phase	--	Phase R	Phase S	Phase T			
	1	90-100%	--	--	--	--	<-1%
	2	10-20%	--	--	--	--	<-1%
	3	0	--	--	--	--	<-1%
Three-phase	--	90-100%	90-100%	90-100%	-242.29	-2.0%	<-1%(-120W)
	--	10-20%	10-20%	10-20%	-270.61	-2.3%	
	--	0	0	0	-288.36	-2.4%	
	--	90-100%	60-70%	60-70%	-1496.47	-12.5%	
	--	60-70%	60-70%	60-70%	-275.01	-2.3%	
	--	30-40%	60-70%	60-70%	-2773.56	-23.1%	
	--	0	60-70%	60-70%	-5381.24	-44.8%	


Remark:

The sum of the tolerance of the power analyzer and current measured are 1%


Tested with energy meter DTSU666

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 1




Graph_Test 2




UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 3




Graph_Test 4




UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict


Graph_Test 5



Graph_Test 6



UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict




UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict


4.2	Response to load disconnections					P		
Test No.	Initial Load	Final load	After disconnection re-adjust time <2s			Frequency [Hz]		
1	90-100%	60-70%	0.578	0.528	0.748	50.00	50.00	50.01
2	90-100%	30-40%	0.756	0.500	0.720	50.00	50.00	49.98
3	90-100%	0-5%	0.422	0.498	0.576	49.99	50.00	50.00
4	60-70%	30-40%	0.878	0.610	0.644	50.00	50.00	49.99
5	60-70%	0-5%	0.496	0.642	0.552	50.00	50.00	50.00
6	30-40%	0-5%	0.712	0.604	0.568	50.01	50.00	50.00

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 1




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 2




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 3




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 4




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 5




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_Test 6



Overview




Zoom in


UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))						
Clause	Requirement – Test			Result – Remark		Verdict
4.3	Response to power increases in the primary energy source					P
Step	Power of generator	load	re-adjust time 			

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 1




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 2




Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 3



Overview




Zoom in

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

4.4	Action in case of loss of communications			P
Test No.	Power of generator	load	Cut off communication re-adjust time <2s	
1	100%	60-70%	0.788	
2	100%	60-70%	0.708	
3	100%	60-70%	0.758	


UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

Test 1



C1 denotes current of Inverter , C2 denotes current of Grid, C3 denotes trip signal of communication.

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))



UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))



C1 denotes current of Inverter , C2 denotes current of Grid, C3 denotes trip signal of communication.

UNE 217001:2020 IN (REQUIREMENTS OF ANEXO I, ITC-BT-40(RD 244/2019))			
Clause	Requirement – Test	Result – Remark	Verdict

4.5	Determination of the maximum number of generators						P
4.1*	Permanent tolerance						P
	Test No.	Load			Power injection to the grid (W)	Tolerance (%)	Limit
Single phase	--	Phase R	Phase S	Phase T			
	1	90-100%	--	--	--	--	<-1%
	2	10-20%	--	--	--	--	<-1%
	3	0	--	--	--	--	<-1%
Three-phase	--	90-100%	90-100%	90-100%	-311.00	-1.24%	<-1%(-120W)
	--	10-20%	10-20%	10-20%	-348.42	-1.39%	
	--	0	0	0	-275.34	-1.10%	
	--	90-100%	60-70%	60-70%	-1557.73	-6.23%	
	--	60-70%	60-70%	60-70%	-324.26	-1.30%	
	--	30-40%	60-70%	60-70%	-2794.68	-11.18%	
	--	0	60-70%	60-70%	-5248.38	-20.99%	

Remark:

The sum of the tolerance of the power analyzer and current measured are 1%

Tested with energy meter DTSU666

*Two generators working in parallel

4.2*		Response to load disconnections						
Test No.	Initial Load	Final load	After disconnection re-adjust time <2s			Frequency [Hz]		
1	90-100%	60-70%	0.524	0.676	0.584	50.00	50.00	50.01
2	90-100%	30-40%	0.568	0.760	0.512	50.00	50.00	49.98
3	90-100%	0-5%	0.432	0.696	0.564	49.98	49.98	49.99
4	60-70%	30-40%	0.500	0.632	0.560	50.00	50.00	49.99
5	60-70%	0-5%	0.628	0.560	0.504	50.00	50.01	50.00
6	30-40%	0-5%	0.552	0.688	0.428	49.99	50.00	49.99


*Two generators working in parallel

t _i (s)	t _r (s)	t _a (s)	N
0.878	0.118	2	10


Appendix: photos



Oversize view



Side view



Bottom view




Connect view



Internal view



Meter view



Meter Label

(End of Report)



中国认可
国际互认
检测
TESTING
CNAS L0220

Test Report issued under the responsibility of:

intertek
Total Quality. Assured.

Page 1 of 30

TEST REPORT UNE 217001 IN: October 2015 Requirements and tests for systems intended to avoid the energy transmission to the distribution network	
Report Reference No	191115099GZU-001
Date of issue	31 Dec 2019
Total number of pages	30 pages
Testing Laboratory	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Address	Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Testing location/ address	Same as above
Tested by (name + signature)	Jason Fu Technical Team Leader
Approved by (+ signature)	Tommy Zhong Technical Manager
Applicant's name	Guangzhou Sanjing Electric Co., Ltd.
Address	No.9, Lizhishan Road, Science City, Guangzhou High-tech Zone, Guangdong, P.R.China
Test specification:	
Standard	UNE 217001 IN: October 2015
Test procedure	Type approval
Non-standard test method	N/A
Test Report Form No.	UNE 217001a
Test Report Form(s) Originator	Intertek Guangzhou
Master TRF	Dated 2019-11
This publication may be reproduced in whole or in part for non-commercial purposes as long as Intertek is acknowledged as copyright owner and source of the material. Intertek takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test item description	Anti-backflow system
Trade Mark	
Manufacturer	Same as Applicant
Model/Type reference	PV Grid-connected Inverter: R5-3K-T2 , R5-4K-T2 , R5-5K-T2 , R5-6K-T2 , R5-8K-T2 , R5-9K-T2 , R5-10K-T2 , R5-12K-T2, R5-13K-T2,R5-15K-T2,R5-17K-T2,R5-20K-T2 Three phase smart meter: DTSU666

Ratings	PV Grid-connected Inverter:						
	Model	R5-3K-T2	R5-4K-T2	R5-5K-T2	R5-6K-T2	R5-8K-T2	R5-9K-T2
	Max Voltage	1100 Vdc					
	MPPT voltage range	160-950 Vdc					
	Max DC input Current [PV1/PV2]	12.5/12.5 Adc					
	Max. Short circuit Current [PV1/PV2]	15/15Adc					
	Nominal AC voltage	3W/N/PE, 230/400Vac					
	Rated AC current [A]	4.4	5.8	7.3	8.7	11.6	13.1
	Max.AC Current [A]	5.0	6.7	8.4	10.0	13.4	15.0
	Grid Frequency	50Hz					
	Rated Power [W]	3000	4000	5000	6000	8000	9000
	Max. AC power [VA]	3300	4400	5500	6600	8800	9900
	Power factor	0.8 Leading to 0.8 Lagging					
	Temperature	-40°C - +60°C					
	Protective Class	Class I					
	Ingress protection	IP 65					
	Software Version	V3.025					
	Model	R5-10K-T2	R5-12K-T2	R5-13K-T2	R5-15K-T2	R5-17K-T2	R5-20K-T2
	Max Voltage	1100 Vdc					
	MPPT voltage range	160-950 Vdc				180-950 Vdc	

Max DC input Current	12.5/12.5 Adc		25/12.5 Adc		25/25 Adc	
Max. Short circuit Current	15/15 Adc		30/15 Adc		30/30 Adc	
Nominal AC voltage	3W/N/PE, 230/400Vac					
Rated AC current [A]	14.5	17.4	18.9	21.8	24.7	29.0
Max.AC Current [A]	16.7	18.2	21.7	25.0	28.4	33.4
Grid Frequency	50Hz					
Rated Power [W]	1000	12000	13000	15000	17000	20000
Max. AC power [VA]	11000	12000	14300	16500	18700	22000
Power factor	0.8 Leading to 0.8 Lagging					
Temperature	-40°C - +60°C					
Protective Class	Class I					
Ingress protection	IP 65					
Software Version	V3.025					

Three phase smart meter:

Voltage: 3 x 230/400V

Current: Max.80A

Frequency: 50/60Hz

Measurement categories: II

Type of communication: RS485

Operational temperature: -40°C - +60°C

Ingress protection: IP 54

Overvoltage category: II

Pollution degree: 2

Software Version: communication: V1.011

Summary of testing:**Tests performed (name of test and test clause):**

All applicable tests

The model R5-20K-T2 is type tested.


Testing location:

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China

Copy of marking plate

 Guangzhou Sanjing Electric Co., Ltd. Tel: +86(20) 66608588 Fax: +86(20) 66608589 Web: www.saj-electric.com E-mail: service@saj-electric.com		
PV Grid-connected Inverter Type: R5-20K-T2		
	PV Input	
	Voltage Range	180V-1100Vdc
	MPPT Voltage Range	180V-950Vdc
	Max. Input Current (PV1/PV2)	25/25Adc
	Max. Short Circuit Current (PV1/PV2)	30/30Adc
	Max. Number of Parallel Strings (PV1/PV2)	2/2
	AC Output	
	Rated Voltage	3/N/PE 380/400V
	Rated Current	3*29.0A
	Max. Continuous Current	3*33.4A
Rated Frequency	50/60Hz	
Rated Power	20000W	
Power Factor	0.8i...1...0.8c	
Temperature: -40℃~60℃ Protective Class: II Overvoltage Category: II (DC), III (AC) Ingress protection: IP65		
EN 50438 EN 50549 VDE-AR-N4105 AS/NZS 4777.2 CEI 0-21		
    		
  		
S/N		
P/C		
MADE IN CHINA		

**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. The other model labels are identical with label above, except the model name and rating.

Test item particulars			
Temperature range	-25°C - 60°C		
AC Overvoltage category	☐ OVC I	☐ OVC II	☒ OVC III ☐ OVC IV
DC Overvoltage category	☐ OVC I	☒ OVC II	☐ OVC III ☐ OVC IV
IP protection class	IP 65		
Possible test case verdicts:			
- test case does not apply to the test object : N/A (Not applicable)			
- test object does meet the requirement..... : P (Pass)			
- test object does not meet the requirement..... : F (Fail)			
Testing			
Date of receipt of test item	15 Nov 2019		
Date (s) of performance of tests	15 Nov 2019 – 30 Dec 2019		
General remarks:			
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. When determining for test conclusion, measurement uncertainty of tests has been considered. This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid. Throughout this report a point is used as the decimal separator.			

General product information:**Description of tested item:**

The equipment is three phase transformerless utility-interactive type PV inverter which will be installed and directly connected to the grid network after installation.


It contains filters for smoothing the output voltage and for EMC, switching and control circuits. Electronic circuits are mounted on a number of PCBs interconnected by appropriate connectors and wires. Power board including electronics components is mounted on the heat sink to earthing by metal screw and spring washer.

There are included a RS485 communication ports which are connected to the wattmeter to monitor the status of the inverter by proprietary software.

The PV input combiner with 2 string MPPT tracers and each MPPT tracer including one PV input terminals. AC output direct connected to grid and Protective Earthing are provided by dedicated earthing terminals. Grid is protected combination with a two series of relays as redundant build for ensure the inverter can independent disconnected from grid while a relay was fault.


During fault condition defined in this standard, after the DSP receives the abnormal signal from the relevant protective detection circuit, the relays will operate to disconnect the PV inverter active lines from grid automatically.

The master DSP and slaver DSP has capacity independent disconnected from grid, when any grid fault had happened.

Block diagram:


Block diagram

Basic outline of the system.



In the grid-connected power generation system, because the user load and light are constantly changing, in order to prevent the grid-connected system from generating electricity in the reverse direction to the power grid, the monitoring meter is added. The inverter communicates with the meter through the RS485 interface to collect the grid-connected port current in real time. And power signals, and calculate the maximum output power limit value of the inverter according to the meter's feedback power and current data, adjust the inverter output power to achieve the anti-backflow function, and maximize the use of photovoltaic modules to generate power;

Control algorithm:



Variable	Statement
Pr	The power detected by the meter. Negative values represent reverse current, while positive values represent absorbed power from the grid.
Pset	Inverter power limit setting
Pinv	Inverter operating output power


$P_{set} = P_{inv} + P_r$; When the current output power of the inverter is greater than the load power, the inverter supplies power to the load and reverses the current to the grid. At this time, it is detected that P_r is negative, and the inverter limit power setting value is reduced;

When the current output power of the inverter is less than the load power, the load must also absorb power from the grid at this time. At this time, it is detected that P_r is a positive value, and the inverter limit power setting value is increased;

Model difference:

The models R5-3K-T2, R5-4K-T2, R5-5K-T2, R5-6K-T2, R5-8K-T2, R5-9K-T2, R5-10K-T2, R5-12K-T2, R5-13K-T2, R5-15K-T2, R5-17K-T2, R5-20K-T2 are identical, which have same control algorithm, same topology diagram and hardware, only the power derating in software.

Test of setup:



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict
4	Requirements		P
4.1	Measurement of energy exchange with the network		P
4.2	Measure of consumption		P
5	Essays		P
5.1	Tolerance in permanent regimes		P
5.2	Response to load disconnections		P
5.3	Response to power increases in the primary energy source		P
5.4	Action in case of loss of communications		P
5.5	Determination of the maximum number of generators	The inverter does not support interconnection. Only an inverter and wattmeter are connected directly to Grid	N/A


UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

5.1	Tolerance in permanent regimes					P
	Load			Power injection to the grid (W)	Tolerance (%)	Limit
	L1	L2	L3			
Single phase	95%	--	--	--	--	<4%
	15%	--	--	--	--	<4%
	0	--	--	--	--	<4%
Three-phase	95%	95%	95%	-219.02	-1.10	<4%
	15%	15%	15%	-66.59	-0.33	<4%
	0	0	0	-72.90	-0.36	<4%
	95%	65%	65%	-2016.70	-10.08	<4%
	65%	65%	65%	-122.11	-0.61	<4%
	35%	65%	65%	-4035.78	-20.18	<4%
	0	65%	65%	-8788.88	-43.94	<4%

Remark:


The sum of the tolerance of the power analyzer and current measured are 4%

Graph_ (95%, 95%, 95%) load




UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_ (15%, 15%, 15%) load




Graph_ (0%, 0%, 0%) load




UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph_ (95%, 65%, 65%) load




Graph_ (65%, 65%, 65%) load



UNE 217001:2015 IN

Graph_ (35%, 65%, 65%) load





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

5.2	Response to load disconnections						P	
Step	Initial Load	Final load	After disconnection re-adjust time <2s			Frequency [Hz]		
1	95%	65%	1.40s	1.45s	1.30s	50.01	50.01	50.01
2	95%	35%	1.40s	1.35s	1.15s	50.01	50.01	50.01
3	95%	0%	0.50s	0.80s	0.85s	50.01	49.97	50.07
4	65%	35%	0.95s	1.00s	1.20s	50.02	50.01	50.01
5	65%	0%	0.60s	0.70s	0.90s	50.01	50.06	50.05
6	35%	0%	0.55	0.70s	0.45s	50.08	50.01	50.01



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 1_95% to 65%





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 2_95% to 35%





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 3_95% to 0%





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 4_65% to 35%





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 5_65% to 0%



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 6_35% to 0%





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

5.3	Response to power increases in the primary energy source					P
Step	Power of generator	load	re-adjust time <2s			
1	45%	65%	See graph 1 (0.85s)	See graph 2 (0.90s)	See graph 3 (0.10s)	
2	55%	65%				
3	65%	65%				
4	75%	65%				
5	85%	65%				
6	95%	65%				



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 1





UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 2



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 3



UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict


5.4	Action in case of loss of communications			P
Step	Power of generator	load	Cut off communication re-adjust time <2s	
1	100%	65%	622.8ms	
2	100%	65%	712.0ms	
3	100%	65%	702.0ms	

UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 1



CH1 denotes current of inverter, CH2 denotes current of load, CH3 denotes current of Grid, CH4 denotes trip signal of communication




UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 2



CH1 denotes current of inverter, CH2 denotes current of load, CH3 denotes current of Grid, CH4 denotes trip signal of communication




UNE 217001:2015 IN			
Clause	Requirement – Test	Result – Remark	Verdict

Graph 3



CH1 denotes current of inverter, CH2 denotes current of load, CH3 denotes current of Grid, CH4 denotes trip signal of communication



Appendix: photos



Front view of inverter



Meter view

End of Report)



本证书证实以下机构

广州三晶电气股份有限公司

广东省广州市高新技术产业开发区科学城荔枝山路9号

已通过中鉴认证有限责任公司的认证，
其质量管理体系符合以下国际质量管理体系标准的要求：

ISO9001:2015

特此准予注册。任何时候，与认证有关的规则和条件均须被遵守

认证范围：

太阳能发电产品（光伏逆变器/储能逆变器）及其配套件的设计开发、
生产及销售；工业控制设备变频器、智能控制系统（智能家居控制器）
的设计开发、生产及其销售

（本证书范围仅包括证书所列场所。若覆盖范围涉及行政许可前置审批、强制性认证的，仅涵盖许可资质、强制性认证证书范围内的产品及服务）

证书签发日期

2022年03月11日

有效日期

2025年03月10日

统一社会信用代码：914401017783916045

证书编号：U0022Q50048R2M

获证组织必须定期接受监督审核并经审核合格此证书方继续有效



胡家华



0158

不遵守UKAS和
UKAS认可组织
的认可标记使
用规定，将可
能导致本证书
失效。



中鉴认证有限责任公司

该证书的所有权属于中鉴认证有限责任公司。

本证书信息可在国家认证认可监督管理委员会官方网站（www.cnca.gov.cn）上查询
证书时效及适用性可向认证机构查询：网址：www.gzcc.org.cn 或致电：020-66390902。
中国广东省广州市广州大道中227号华景大厦4楼（510600）中鉴认证有限责任公司



GUANGZHOU SANJING ELECTRIC CO., LTD.

NO.9, LIZHISHAN ROAD, SCIENCE CITY, HIGH-TECH. INDUSTRIAL DEVELOPMENT ZONE,
GUANGZHOU CITY, GUANGDONG PROVINCE

*Has been assessed by Zhongjian Certification Co., Ltd
in respect of their Quality Management
Systems and to comply with:*

ISO9001:2015

*Approval is hereby granted for registration providing the
rules and conditions relating to certification are observed at
all times*

CERTIFICATION SCOPE:

DESIGN, DEVELOPMENT, MANUFACTURE AND SALE OF SOLAR POWER GENERATION PRODUCTS
(PHOTOVOLTAIC INVERTERS/ENERGY STORAGE INVERTER) AND ACCESSORIES; DESIGN,
DEVELOPMENT, MANUFACTURE AND SALE OF FREQUENCY INVERTER FOR INDUSTRIAL CONTROL
MACHINERY EQUIPMENT, INTELLIGENT CONTROL SYSTEM (SMART HOME CONTROLLER)

(This certificate only covers the sites listed. If the covered scope involves pre-approval of administration permit or compulsory certification requirement, the scope only covers products and services within the permit license or compulsory certification scope)

Date of Issue

2022-03-11


Valid Until

2025-03-10

Certificate Number: U0022Q50048R2M

Organization Code: 914401017783916045

This certificate remains valid only if the certified organization accepts and passes regular surveillance audits.




Handwritten signature of the authorized representative.

Authorised Signature for
ZhongJian Certification Co., Ltd



0158

Lack of fulfillment of
condition as set out
in Condition for the
Use of National
Accreditation Marks
by UKAS and UKAS
Accredited
Organizations may
render this
certificate invalid



This certificate remains the property of
Zhongjian Certification Co., Ltd of Quality System

The validity of this certificate could be confirmed via official Website Of CNCA (www.cnca.gov.cn)
Further to the certificate applicability, please enquire the certified organization: visit www.gzcc.org.cn or contact GZCC 020-66390902
4/F, Huajing Building, Guangzhou Dadaozhong, Guangzhou City, Guangdong Province, China (510600) Zhongjian Certification Co., Ltd.



Zhongjian Certification Co., Ltd.

CERTIFICATE OF CONFORMITY OF ENVIRONMENTAL MANAGEMENT SYSTEM CERTIFICATION

No:0070023E50463R2M

This is to certify that the environmental system of

GUANGZHOU SANJING ELECTRIC CO., LTD.

NO.9, LIZHISHAN ROAD, SCIENCE CITY, HIGH-TECH. INDUSTRIAL DEVELOPMENT ZONE, GUANGZHOU CITY, GUANGDONG
PROVINCE

Organization Code: 914401017783916045

is in conformity with

GB/T 24001-2016/ISO14001:2015 Standard

This system is valid for the

THE RELATIVE MANAGEMENT ACTIVITIES OF DESIGN, DEVELOPMENT, MANUFACTURE AND SALE OF SOLAR
POWER GENERATION PRODUCTS (PHOTOVOLTAIC INVERTERS/ENERGY STORAGE INVERTER) AND ACCESSORIES;
DESIGN, DEVELOPMENT, MANUFACTURE AND SALE OF FREQUENCY INVERTER FOR INDUSTRIAL CONTROL
MACHINERY EQUIPMENT, INTELLIGENT CONTROL SYSTEM (SMART HOME CONTROLLER)

(This certificate only covers the sites listed. If the covered scope involves pre-approval of administration permit or compulsory certification requirement, the scope only covers products and services
within the permit license or compulsory certification scope)

Date of issue: 2023-03-14

Term of validity of this certificate: from 2023-03-14 to 2026-03-13 inclusive

This certificate remains valid only if the certified organization accepts and passes regular surveillance audits.



Representative of The Company



中国认可
国际互认
管理体系
MANAGEMENT SYSTEM
CNAS C007-M

The validity of this certificate could be confirmed via official Website Of CNCA (www.cnca.gov.cn)
Further to the certificate applicability, please enquire the certified organization: visit www.gzcc.org.cn or contact GZCC 020-66390902
4/F, Huajing Building, Guangzhou Dadaozhong, Guangzhou City, Guangdong Province, China (510600) Zhongjian Certification Co., Ltd.